

SSO Notification List

June 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	6/1/2012	2557 McHenry St	21223	Old Style Trap	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet on ground covered trap	Evidence of Overflow	Left plumber notice to correct problem	Need a plumber	95682
2	6/2/2012	3315 Oakfield Ave	21207	Rags & Trash	DWO	Gwynns Falls	0:40	3:00PM - 3:40PM	Gray & Brown Colored Water	80	Pressure Jet relieved Mainline choke	Turn over to CCTV	139947
3	6/2/2012	4002 Kathland Ave	21216	Rags, Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139963
4	6/4/2012	5704 Adleigh Ave	21206	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet on ground around clean-out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140027
5	6/6/2012	2453 Barley St	21218	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper on ground	Evidence of Overflow	Left plumber notice to correct problem	Need a plumber	140130
6	6/6/2012	1147 Monroe Cir	21225	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140157
7	6/8/2012	2801 St. Lo Dr.	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet on ground near manhole	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140228
8	6/8/2012	5263 Cordelia Ave	21215	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140267
9	6/9/2012	5101 Harford Rd	21214	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Rags & Water near clean-out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140287
10	6/10/2012	5900 Greenspring Ave	21209	Rags & Roots	DWO	Jones Falls	1:02	9:58AM - 11:00AM	Heavy Gray Water	310	Pressure Jet relieved Mainline choke	Turn over to CCTV	140290
11	6/10/2012	517 N. Carrollton Ave	21223	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140293
12	6/11/2012	700 Mliyer Ln	21229	Debris	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	140329
13	6/11/2012	5612 Park Heights Ave	21215	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140331
14	6/12/2012	4811 Frankford Ave	21206	Rags & Trash	WWO	Herring Run	14:10	6/12/12 7:15PM - 6/13/12 9:25AM	Brown & Gray Colored Water	2,550	Pressure Jet relieved Mainline choke	Turn over to CCTV	140396
15	6/13/2012	2807 Overland Ave	21214	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140425
16	6/13/2012	4713 Frederick Ave	21229	Mud	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137409
17	6/14/2012	Falls Rd & W. Northern Pkwy	21210	Rags	DWO	Jones Falls	4:20	4:55PM - 9:15PM	Sewer Water	1,300	Pressure Jet relieved Mainline choke	Turn over to CCTV	140487
18	6/15/2012	4707 Falls Rd	21209	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140524
19	6/16/2012	402 Key Highway	21230	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Small amount of tissue	Evidence of Overflow	Pressure Jet relieved Mainline choke	N/A	140279
20	6/16/2012	938 Wilmington Ave	21223	Rags & Roots	DWO	Gwynns Falls	3:24	9:36AM - 1:00PM	Heavy Gray Water	408	Pressure Jet relieved Mainline choke	Turn over to CCTV	140542
21	6/17/2012	1933 W. Fayette St	21223	Rags & Roots	DWO	High Level	23:54	6/17/12 1:06PM - 6/18/12 1:00PM	Heavy Gray Water	2,868	Electric Machine relieved House Connection choke	Turn over to CCTV	140553
22	6/17/2012	28 N. Decker Ave	21224	Grease & Debris	DWO	Low Level	4:24	7:36AM - 12:00PM	Heavy Gray Water	528	Pressure Jet relieved Mainline choke	Turn over to CCTV	140570
23	6/17/2012	708 Harvey St	21230	Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Light Water & Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	140587
24	6/19/2012	6300 Boston St	21224	Rags & Grease	DWO	None	1:00	10:00AM - 11:00AM	Gray Colored Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	140657
25	6/19/2012	2216 Deerfern Crescent	21209	Roots & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140658
26	6/20/2012	2803 Elgin Ave	21216	Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140702
27	6/21/2012	2859 Woodbrook Ave	21209	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet spot on ground around clean-out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140773

SSO Notification List

June 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	6/21/2012	4511 Wakefield Rd	21216	Rags, Roots & Grease	DWO	Gwynns Falls	3:30	3:00PM - 6:30PM	Gray Water Grease	840	Pressure Jet relieved Mainline choke	Turn over to CCTV	140793
29	6/22/2012	4507 Wakefield Rd	21216	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Waste Toilet Paper & Sanitary Napkins	Evidence of Overflow	Turn over to the Health Dept.	Need a plumber	140837
30	6/23/2012	906 Ashburton St	21216	Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Grease	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140858
31	6/23/2012	411 N. Bouldin St	21224	Grease & Trash	WWO	Northwest Passage	1:20	5:10PM - 6:30PM	Clear Colored Water	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	140874
32	6/23/2012	2807 Overland Ave	21214	Pipe Break	WWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140875
33	6/24/2012	502 Albemarle St	21202	Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	140891
34	6/24/2012	1108 E. Coldspring Ln	21239	Rags, Roots & Trash	WWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140898
35	6/25/2012	2536 McHenry St	21223	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140946
36	6/25/2012	1424 W. Mount Royal Ave	21217	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	140941
37	6/26/2012	1150 N. Carroliton Ave	21217	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	By Pass Pumping	140973
38	6/26/2012	2231 Rogene Dr	21209	Rags	DWO	Jones Falls	2:00	12:48PM - 2:48PM	Heavy Gray Water	240	Electric Machine relieved House Connection choke	Turn over to CCTV	140982
39	6/27/2012	29 N. Kresson St	21224	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Side walk wet	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	141020
40	6/27/2012	1234 S. Carey St	21230	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	141035
41	6/28/2012	2803 Elgin Ave	21216	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	141070
42	6/28/2012	950 Bennett Pl	21223	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	141073
43	6/29/2012	2803 Elgin Ave	21216	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	Need a plumber	141129
				# WWO	12				TOTAL	9,424	EVIDENCE ONLY	32	